

Annual Drinking Water Quality Report for the Year 2025

Monroe Township Utility Department - For the Year 2025, Results from 2024

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We currently operate nine groundwater wells. Four of our groundwater wells are located in the Old Bridge Sand Aquifer System and five are in the Farrington Sand Aquifer System. We no longer purchase water from New Jersey American Water.

If you are a landlord, you must distribute this Drinking Water Quality Report to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to Section #3 of NJ P.L. 2012, c.82 (C.58:12A-12.4 et seq.).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Monroe Township Utility Department Test Results – PWS ID#NJ1213002

Contaminant	Violation	Level Detected	Unit of Measure	MCLG	MCL	Likely Source
Inorganic Contaminants:						
Barium	N	Range = ND - 0.0119 Highest Detect = 0.0119	ppm	0	2	Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits
Beryllium, Total	N	Range = ND - 0.0003 Highest Detect = 0.0003	ppm	0.004	0.004	Discharge from metal refineries and coal burning factories, discharge from electrical, aerospace, and defense industries.
Copper Test Results 2024 Results in 90th Percentile	N	0.284 No samples exceeded the action level.	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Test Results 2024 Results in 90th Percentile	N	Range = ND - 2.46 No samples exceeded the action level.	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Nickel Test Results 2024	N	Range = ND - <0.001 Highest Detect = <0.001	ppm	NA	NA	Erosion of natural deposits
Nitrate/Nitrite	N	Range = ND - 3.25 Highest Detect = 3.25	ppm	10	10	Runoff from fertilizer use, leaching from septic tanks, sewage, erosion of natural deposits
Thallium, Total	N	Range = ND - 0.0003 Highest Detect = 0.0003	ppm	0.0005	0.002	Leaching from ore producing sites, discharge from electronics, glass, and drug factories.

Disinfection Byproducts:						
TTHM Total Trihalomethanes	N	Range = ND – 6.46 Highest - 6.46 Average – 2.61	ppb	NA	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids	N	Range = ND – 1.58 Highest – 1.58 Average – 0.098	ppb	NA	60	By-product of drinking water disinfection
Radioactive Contaminants:						
Combined Radium 228 & 226	N	Range = ND – 5.1 Highest - 5.1 Average – 1.04	pCi/L	0	5	Erosion of natural deposits
Gross Alpha	N	Range = ND - 10.4 Highest - 10.4 Average – 3.41	pCi/L	0	15	Erosion of natural deposits
PFAS Pre- and Polyfluoroalkyl Substances:						
PFOA	N	Range = ND – 11 Highest = 12 Average = 7.68	ppt	0	14	Discharge from industrial, chemical, and manufacturing factories, releases from aqueous film forming foam
PFOS	N	Range = ND – 14 Highest = 14 Average = 3.3	ppt	0	13	Discharge from industrial, chemical, and manufacturing factories, releases from aqueous film forming foam
Regulated Disinfectants:		Levels Detected		MRDL		MRDLG
Chlorine	N	Range= 0.5 - 1.0 Average= 0.67		4.0 ppm		4.0 ppm

Chlorine: Water additive used to control microbes.

HAA5 and TTHM compliance is based on the Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

Secondary Contaminants:	Levels Detected	Unit of Measure	RUL
Sodium	Range = 2.7 – 35.9	PPM	50
Odor	Range = ND - <1 TON Highest = <1 TON Average = <1 TON	TON	3

Unregulated Contaminants for which EPA Required Monitoring

The Monroe Township Utility Department participated in the Unregulated Contaminant Monitoring Rule (UCMR) in 2025. Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Unregulated Contaminants (UCMR5) - Sample Event 1 of 2

Contaminant:	Levels Detected	Units of Measure	Likely Source
perfluorobutonic acid (PFBA)	Range = ND – 0.008 Average = 0.00294	ppb	Discharge from industrial, chemical, and manufacturing factories, releases from aqueous film forming foam
perfluoroheptanoic acid (PFHpA)	Range = ND – 0.0049 Average = 0.00133	ppb	
perfluorohexanesulfonic acid (PFHxS)	Range = ND - 0.015 Average = 0.002325	ppb	
perfluorohexanoic acid (PFHxA)	Range = ND- 0.0052 Average = 0.00193	ppb	
perfluoropentanoic acid (PFPeA)	Range=ND – 0.00655 Average = 0.00295	ppb	
perfluorooctanoic acid (PFOA)	Range = ND – 0.011 Average = 0.0039	ppb	
perfluorooctanesulfonic acid (PFAS)	Range = ND – 0.015 Average = 0.0025625	ppb	

The New Jersey Department of Environmental Protection has completed Source Water Assessment Reports and Summaries for these public water systems, which are available at www.state.nj.us/dep/swap or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system to obtain information regarding these water systems Source Water Assessments. The Monroe Township Utility Department's source water susceptibility ratings and a list of potential contaminant sources is included.

What are PFOA and PFOS?

Perfluorooctanoic acid (PFOA) and perfluorooctane sulfonate (PFOS) are per- and polyfluoroalkyl substances (PFAS), previously referred to as perfluorinated compounds, or PFCs, that are man-made and used in industrial and commercial applications. PFOA was used as a processing aid in the manufacture of fluoropolymers used in non-stick cookware and other products, as well as other commercial and industrial uses based on its resistance to harsh chemicals and high temperatures. PFOS is used in metal plating and finishing as well as in various commercial products. PFOS was previously used as a major ingredient in aqueous film forming foams for firefighting and training, and PFOA and PFOS are found in consumer products such as stain resistant coatings for upholstery and carpets, water resistant outdoor clothing, and grease proof food packaging. Although the use of PFOA and PFOS has decreased substantially, contamination is expected to continue indefinitely because these substances are extremely persistent in the environment and are soluble and mobile in water. More information can be found at: [https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs_PFOA-PFOS-websites-OLA%204-24-19SDM-\(003\).pdf](https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs_PFOA-PFOS-websites-OLA%204-24-19SDM-(003).pdf)

pH

Monroe Township Utility Department's - pH range is (7.3 – 8.1). You may have heard the word “pH” used to describe drinking water quality, but do you know what it means?

pH is a measurement of electrically charged particles in a substance. It indicates how acidic or alkaline (basic) that substance is. The pH scale ranges from 0 to 14.

- Acidic water has a pH lower than 7. The most acidic substances have a pH of 0. Battery acid falls into this category.
- Alkaline water has a pH of 8 or above. The most alkaline substances, such as lye, have a pH of 14.
- Pure water has a pH of 7 and is considered “neutral” because it has neither acidic nor basic qualities.

The US Environmental Protection agency (EPA) oversees the monitoring for public drinking water quality across the United States. pH isn't a quality that falls under EPA regulation because it's considered an aesthetic quality of water, however, the agency recommends that municipal drinking water suppliers keep their water supply at a pH 6.5 – 8.5.

The Monroe Township Utility Department routinely monitors for contaminants in your drinking water according to Federal and State laws. The table shows the results of that monitoring for the period of January 1, 2024 to December 31, 2024. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants does not change frequently.

The New Jersey Department of Environmental Protection (NJDEP) has completed Source Water Assessment Reports and Summaries for these public water systems, which are available at <https://www.nj.gov/dep/watersupply/swap/index.html> or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system to obtain information regarding these water systems Source Water Assessments. The Monroe Township Utility Department's source water susceptibility ratings and a list of potential contaminant sources is included.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas projection, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791. The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. Our system received a monitoring waiver for synthetic organic contaminants.

Definitions:

In the "Test Results" table you may find some terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or nanogram per liter - one part per trillion corresponds to one minute in 20,000 years, or a single penny in \$100,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Secondary Contaminant- Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Recommended Upper Limit (RUL) – Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RULs are recommendations, not mandates.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Threshold Odor Number (TON) – The greatest dilution of a sample with odor-free water that still yields a just-detectable odor.

Sources of Lead in Drinking Water

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Monroe Township Utility Department is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact The Monroe Township Utility Department at (732) 521-1700. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

The Monroe Township Utility Department is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. Although most lead exposure occurs from inhaling dust or from contaminated soil, or when children eat paint chips, the U.S. Environmental Protection Agency (USEPA) estimates that 10 to 20 percent of human exposure to lead may come from lead in drinking water. Infants who consume mostly mixed formula can receive 40 percent to 60 percent of their exposure to lead from drinking water. Lead is rarely found in the source of your drinking water but enters tap water through corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing materials. These materials include lead-based solder used to join copper pipes, brass, and chrome-brass faucets, and in some cases, service lines made of or lined with lead. New brass faucets, fittings, and valves, including those advertised as "lead-free", may still contain a small percentage of lead, and contribute lead to drinking water. The law currently allows end-use brass fixtures, such as faucets, with up to 0.25 percent lead to be labeled as "lead free". However, prior to January 4, 2014, "lead free" allowed up to 8 percent lead content of the wetted surfaces of plumbing products including those labeled National Sanitation Foundation (NSF) certified. Visit the NSF website at www.nsf.org to learn more about lead-containing plumbing fixtures. Consumers should be aware of this when choosing fixtures and take appropriate precautions. When water stands in lead service lines, lead pipes, or plumbing systems containing lead for several hours or more, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon if the water has not been used all day, can contain fairly high levels of lead.

Steps You Can Take to Reduce Exposure to Lead in Drinking Water

For a full list of steps visit: <http://www.epa.gov/safewater/lead>

Run the cold water to flush out lead. Let the water run from the tap before using it for drinking or cooking any time the water in the faucet has gone unused for more than six hours. The longer the water resides in plumbing the more lead it may contain.

Flushing the tap means running the cold-water faucet. Let the water run from the cold-water tap based on the length of the lead service line and the plumbing configuration in your home. In other words, the larger the home or building and the greater the distance to the water main (in the street), the more water it will take to flush properly. Although toilet flushing or showering flushes water through a portion of the plumbing system, you still need to flush the water in each faucet before using it for drinking or cooking. Flushing tap water is a simple and inexpensive measure you can take to protect your health. It usually uses less than one gallon of water.

Use cold, flushed water for cooking and preparing baby formula. Because lead from lead-containing plumbing materials and pipes can dissolve into hot water more easily than cold water, never drink, cook, or prepare beverages including baby formula using hot water from the tap. If you have not had your water sampled or if you know, it is recommended that bottled or filtered water be used for drinking and preparing baby formula. If you need hot water, draw water from the cold tap and then heat it.

Do not boil water to remove lead. Boiling water will not reduce lead; however, it is still safe to wash dishes and do laundry. Lead will not soak into dishware or most clothes.

Use alternative sources or treatment of water. You may want to consider purchasing bottled water or a water filter. Read the package to be sure the filter is approved to reduce lead or contact NSF International at 800-NSF-8010 or www.nsf.org for information on performance standards for water filters.

Determine if you have interior lead plumbing or solder. If your home/building was constructed prior to 1987, it is important to determine if interior lead solder or lead pipes are present. You can check yourself, hire a licensed plumber, or check with your landlord.

Replace plumbing fixtures and service lines containing lead. Replace brass faucets, fittings, and valves that do not meet the current definition of "lead free" from 2014 (as explained above). Visit the NSF website at www.nsf.org to learn more about lead-containing plumbing fixtures.

Remove and clean aerators/screens on plumbing fixtures. Over time, particles and sediment can collect in the aerator screen. Regularly remove and clean aerators screens located at the tip of faucets and remove any particles.

Test your water for lead. Please call 732-521-1700 to find out how to get your water tested for lead. Testing is essential because you cannot see, taste, or smell lead in drinking water.

Get your child tested. Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. New Jersey law requires that children be tested for lead in their blood at both 1 and 2 years of age and before they are 6 years old if they have never been tested before or if they have been exposed to a known source of lead.

Have an electrician check your wiring. If grounding wires from the electrical system are attached to your pipes, corrosion may be greater. Check with a licensed electrician or your local electrical code to determine if your wiring can be grounded elsewhere. DO NOT attempt to change the wiring yourself because improper grounding can cause electrical shock and fire hazards.

Water softeners and reverse osmosis units will remove lead from water but can also make the water more corrosive to lead solder and plumbing by removing certain minerals; therefore, the installation of these treatment units at the point of entry into homes with lead plumbing should only be done under supervision of a qualified water treatment professional.

Health Effects of Lead

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development. Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. You can find out more about how to get your child tested and how to pay for it at <https://www.state.nj.us/health/childhoodlead/testing.html>

In July 2021, P.L.2021, Ch.183 (Law) was enacted, requiring all community water systems to replace lead service lines in their service area within 10 years. Under the law, The Monroe Township Utility Department is required to notify customers, non-paying consumers, and any off-site owner of a property (e.g., landlord) when it is known they are served

by a lead service line*. Our service line inventory is available on our website at <https://www.monroetud.com> or upon request.

Monroe Township Utility Department – PWSID NJ1213002

The Monroe Township Utility Department is a public community water system consisting of nine wells. This system's source water comes from the following aquifers: Old Bridge Sand Aquifer and the Farrington Sand Aquifer. This system can purchase water from the following water system: New Jersey American Water.

Susceptibility Ratings for Monroe Township Utility Department Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes' susceptibility to radionuclides was not determined and they all received a low rating.

If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfection Byproduct Precursors		
Sources	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L
Wells - 9		1	8	8	1			3	6		5	4		6	3	5	1	3	5	1	3		7	2

Pathogens: Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

Nutrients: Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Volatile Organic Compounds: Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Pesticides: Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Inorganics: Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

Radionuclides: Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.html> or call (800) 648-0394.

Disinfection Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.

If you have questions about your water, please call us at 732-521-1700. Additional information is also available on our website at <https://www.monroetud.com>. Monthly Council meetings are generally held on the first Monday of each month at 7:00 P.M. Visit the Township website at <https://www.monroetwp.com> to see the schedule for upcoming meetings. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.



Township of Monroe

County of Middlesex

UTILITY DEPARTMENT

143 Union Valley Road
Monroe Township, NJ 08831
(732) 521-1700 • (609) 655-1050
(609) 655-5981 FAX

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Monroe Township Utility Department

On August 6, 2024 we became aware that our system recently failed to collect the correct number of drinking water samples. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the first quarter of 2024, monitoring requirements for TP015038 associated with PFOA, PFOS and PFNA were changed from an annual frequency to quarterly as a result of detectable levels of these components being measured in the annual sample. It should be noted that these detectable levels were well below the States Regulatory Standard of 13 and 14 parts per trillion, respectively. Accordingly, the Utility could not report the levels of these synthetic Organic Compounds during this quarter. We have since taken the required quarterly samples for TP015038 and all subsequent samples have had non-detectable levels of PFOA, PFOS and PFNA.

What should I do?

There is nothing you need to do.

What is being done?

As stated above, monitoring is being done quarterly. Each quarterly sample is collected at the point of entry into the Distribution System and tested by a State approved, certified laboratory in accordance with the approved methods established by the Environmental Protection Agency.

For more information, please contact the Monroe Township Utility Department at (732) 521-1700.

This notice will be uploaded to our website, www.monroetwp.com/index.php/departments/municipal-utility-dept and as an attachment to our 2025 Consumer Confidence Report-Annual Drinking Water Quality Report. Our Consumer Confidence Report is posted on the bulletin boards of all Monroe Township public buildings and private residential community centers throughout Monroe Township, on our website, and a link is printed onto our residential and commercial water and sewer bills.

This notice is being distributed by:

Monroe Township Utility Department
143 Union Valley Road
Monroe Township NJ 08831
New Jersey State Water System ID # NJ1213002

Date distributed: June 16, 2025